

Attachment: 4019 Determination of Thermal Shock and Thermal Shock Endurance for Glass Containers

4019 Determination of Thermal Shock and Thermal Shock Endurance for Glass Containers

Thermal shock (also known as thermal-shock resistance) refers to the difference between the temperature at which the sample is heated (upper limit temperature t_1) and the temperature of the cold water bath in which the sample is placed (lower limit temperature t_2).

Thermal shock endurance refers to the temperature difference when 50% of the glass container are broken in thermal shock test.

This method applies to the determination of thermal shock and thermal shock endurance of glass containers for pharmaceutical use.

Based on the temperature difference, the determination methods can be divided into cold and hot water baths method, and oven method.

Method I. Cold and hot water baths method

This method applies to all kinds of glass containers for pharmaceutical use, whose test temperature difference is less than 100°C.

Instruments: Hot water bath: The capacity shall be at least twice of the total volume of the samples in one test and shall not be less than 5 L. The water bath shall contain water circulators, temperature control components, and heaters for temperature regulation to keep the water temperature stable within the upper limit temperature $t_1 \pm 1^\circ\text{C}$.

Cold water bath: The capacity shall be at least five times of the total volume of the samples in one test. The water bath shall contain water circulators, temperature control components, and thermostatic controllers to ensure that the water temperature is stable within the lower limit temperature $t_2 \pm 1^\circ\text{C}$.

Net basket: The material of the net basket (coated if necessary) shall not scratch or rub the samples during the test. The net basket shall be able to hold the glass samples upright and separated from each other, and be equipped with a device to fix the samples and prevent them from floating when immersed.

Determination

(1)The samples, which shall be free from any glass defects, should be untested for other properties (such as mechanical, thermal properties, etc.), and be placed in the test environment for at least 30 minutes in advance to ensure that the temperature of the samples is consistent with the environment.

(2)Fill the two water baths (for cold and hot water bath, respectively) with sufficient water to submerge the top of the containers by at least 50 mm, then regulate the water temperature to t_1 and t_2 , respectively. Generally, the water temperature of t_2 is 0°C - 27°C , and the selected t_1 shall be able to obtain the desired thermal shock temperature difference $t_1 - t_2$ ($^\circ\text{C}$). The temperature difference between t_1 and t_2 shall not exceed $\pm 1^\circ\text{C}$ of the specified value during the process where samples, placed in a net basket, are transferred from the hot water bath to the cold water bath

(3)First place the samples in a net basket, keep them upright and separated, then immerse them in the hot water bath with a temperature of t_1 , fill the samples with water, and keep the top of the bottle mouth at least 50 mm below the water surface. Allow the samples to soak for at least 5 minutes to ensure that the temperature equilibrium is reached between the samples and the water.

46 Experience has shown that the time required to reach temperature equilibrium depends on
47 the maximum thickness of the samples. To ensure that both sides of the sample wall are heated,
48 it takes at least 30 seconds per mm of wall thickness to reach temperature equilibrium.

49 (4) Transfer the samples filled with water in the net basket from the hot water bath to the
50 cold water bath with a temperature of t_2 quickly. The transfer process of the samples must be
51 completed within $10\text{ s} \pm 2\text{ s}$.

52 (5) The samples immersed in the cold water bath for 30 seconds. Then take out the net
53 basket, together with the samples, from the cold water bath. The samples taken from the cold
54 water bath shall be inspected immediately. Only those samples without breakage, crack or
55 damage can be adjudicated as qualified products.

56 The qualified samples shall not be used in other tests. If the temperature of the hot water
57 bath has reached to 95°C during the test, the test can be continued by lowering the temperature of
58 the cold water bath.

59 **Method II. Oven method**

60 This method applies to all kinds of glass containers for pharmaceutical use whose test
61 temperature difference is 80°C or higher.

62 **Instruments:** Oven: the temperature can reach to at least 300°C , and equipped with air
63 stirrers or circulators to ensure that the temperature variation does not exceed $\pm 5^\circ\text{C}$. The oven
64 must be equipped with an automatic temperature regulator, which can keep the temperature
65 fluctuation within $\pm 1^\circ\text{C}$ when the temperature is below or equal to 180°C , and can keep the
66 temperature fluctuation within $\pm 2^\circ\text{C}$ when the temperature is at $180\text{-}300^\circ\text{C}$.

67 Cold water bath: With the same requirements for the cold water bath as Method I. Net
68 basket: With the same requirements for the net basket as Method I. Clamps: the heads are
69 wrapped with heat-insulating materials, keep the clamps dry when in use.

70 **Determination**

71 (1) The samples should be untested for other properties (such as mechanical, thermal
72 properties, etc.) and be placed in an oven preheated to the upper temperature, t_1 , for at least 30
73 minutes to ensure that the temperature of the samples reaches equilibrium with that of the oven.

74 Experience has shown that the time required to reach temperature equilibrium depends on
75 the maximum thickness of the samples. To ensure that both sides of the sample wall are heated,
76 it takes at least 6 minutes per mm of wall thickness to reach temperature equilibrium.

77 (2) Use the clamps with insulated heads to take out the samples from the oven, or take out
78 the net basket together with samples from the oven if two or more samples are tested at the same
79 time. Submerge the samples (or together with the net basket) in the cold water tank to half of the
80 height (for bottles with necks, half of the total height excluding the necks) and hold for 30 s. The
81 cold water bath shall be close to the oven and kept at the lower temperature, t_2 , at $0\text{-}27^\circ\text{C}$. The
82 difference between this value of temperature difference and the temperature difference required
83 when the samples are placed into the cold water bath shall not be greater than $\pm 3^\circ\text{C}$. The transfer
84 process of each sample must be completed within $5\text{ s} \pm 1\text{ s}$.

85 The transfer process refers to the period from when the oven is being opened until the
86 samples are immersed in cold water.

87 (3) The samples taken from the cold water bath shall be inspected immediately. The samples
88 without breakage, crack or damage can be adjudicated as qualified.

89 The qualified samples shall not be used in other tests.

90 **Result Evaluation**

91 Thermal shock: After thermal shock test with specified temperature t_1 and t_2 , if the number
92 of broken samples is less than the specified number, it is adjudicated as qualified.

93 Thermal shock endurance: Expressed as the temperature difference at which 50% of the
94 samples are broken by repeating the test with a temperature increment of 5-10°C each time
95 following the above test steps. If the temperature difference meets the specified requirements, it
96 is adjudicated as qualified. The value of the temperature difference can be obtained from the
97 curve drawn with the cumulative percentage of broken vs. the corresponding temperature
98 difference.

Drafted by: National Institutes for Food and Drug Control Contact number: 010-67095110